



RECEIVED
NOV 29 2012
DIVISION OF ENERGY REGULATION
STATE CORPORATION COMMISSION

November 26, 2012

Mr. William F. Stephens
Director of the Division of Energy Regulation
Commonwealth of Virginia State Corporation Commission
PO Box 1197
Richmond, VA 23218

RE: Fauquier Livestock Exchange Solar Photovoltaic System

Dear Mr. Stephens:

The purpose of this letter is to inform the State Corporation Commission (SCC) that an electric generating facility has been installed at the Fauquier Livestock Exchange located at 7404 John Marshall Highway in Marshall, Virginia.

Pursuant to 20VAC5-302-10 the specifications of this facility are as follows:

Address: 7404 John Marshall Highway, Marshall, VA 20115
Nameplate Capacity: 218,880 kW-DC
Module Type: PowerBond PVL – 144
Number of Modules: 1520
Inverter Types: Fronius IG Plus 10.0-1 and Solectria PVI 95kW Commercial Inverter
Number of Inverters: 3 Fronius and 2 Solectria (5 total)
Estimated Annual Production: 284,544 kWh

Northern Virginia Electric Cooperative (NOVEC) has designated this system as "Agricultural Use", and has inspected, installed the net-meter, and accepted the interconnection with their transmission network. Infinite Green Energy llc successfully commissioned the system on April 1, 2012, and began net-metering operation with NOVEC on April 20, 2012. Energy production measured during commissioning was above design levels for the entire system.

Regards,

A handwritten signature in black ink, appearing to read "Chris Hines", is written over a faint, illegible typed name.

Christopher L. Hines
President